

May 21, 2007

WATTS REGULATOR CO.
KATHY KELLEY
815 CHESTNUT ST
NORTH ANDOVER MA 01845-6098

ANDERSON-BARROWS
J.D.HALL
2800 ANDERSON AV.
PALMDALE CO 93550

Re: Description: FIXTURE OR APPLIANCE SUPPLY CONNECTOR
Manufacturer: ANDERSON-BARROWS
Product Name: NONE
Model Number(s): CDC-S-CE, CFC-S-FF, CFC-S-TF, CTC-S-CB, CTC-S-FB, CTC-S-TB, CWH-S-AF, CWH-S-AM, CWH-S-FF, CWH-S-FM AND CWM-S-HL SERIES
CDC-S-CE 1/2" X 3/8" X 48" THRU 72" CTC-S-CB 3/8" X 7/8" X 6" THRU 20"
CFC-S-FF 1/2" X 1/2" X 12" THRU 24" CFC-S-CO 3/8" X 1/2" X 12" AND 20"
CFC-S-TF 3/8" X 1/2" X 12" THRU 24" CFC-S-TF 1/2" X 1/2" X 12" THRU 24"
CTC-S-CB 7/16" X 7/8" X 6" THRU 20" CTC-S-CB 1/2" X 7/8" X 6" THRU 20"
CTC-S-FB 1/2" X 7/8" X 6" THRU 20" CTL-S-CB 1/2" X 7/8" X 6" THRU 12"
CTC-S-TB 3/8" X 7/8" X 6" THRU 20" CTC-S-TB 1/2" X 7/8" X 6" THRU 20"
CWH-S-AF 5/8" X 1" X 12" THRU 24" CWH-S-AA 7/8" X 7/8" X 12" THRU 24"
CWH-S-AM 7/8" X 1" X 12" THRU 24" CWM-S-HH 1" X 1" X 48" THRU 72"
CWH-S-FF 1" X 1" X 12" THRU 72" CWH-S-AF 7/8" X 1" X 12" THRU 72"
CWH-S-FM 1" X 1" X 12" THRU 24" CWH-S-AM 5/8" X 1" X 12" THRU 24"
CWM-S-HL 1" X 1" X 48" THRU 72" CDC-S-CE 3/8" X 3/8" X 48" THRU 72"
CDC = DISHWASHER CONNECTORS, CFC = FAUCET CONNECTORS, CTC = TOILET CONNECTORS, CWH = WATER HEATER CONNECTORS, CWM = WASHING MACHINE CONNECTORS
Product File No: 20070229

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 84.30(4) based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of May 2012.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This product may only be installed in exposed areas.
- This product may be installed for the following water use(s):
 - a. Fixture supply connector Aboveground
 - b. Water distribution piping Aboveground

This approval supersedes the approval issued on April 15, 2002, under product file number 20020116.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20020116.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE
Plumbing Product Reviewer
phone: 608-266-6742, fax: 608-267-9566, e-mail: mike.beckwith@wisconsin.gov
SBD-10564-E (N.10/97)

File Ref: 07022902.DOC